

Chlorothalonil Metabolit								
Probenahme		16.04.2024	28.05.2024	28.05.2024	07.10.2024	05.11.2024	26.11.2024	
Labor		Wessling	Wessling	Nacua	Wessling	Wessling	Nacua	
TDBV Höchstwert	0.1 µg/l							Mittelwert
Rüderswil Quelle								
Chlorthalonil-M4 (R471811)	µg/l	0.074			<0.05			0.07
Chlorthalonil-M12 (R417888)	µg/l	<0.02			<0.02			<0.02
Rüderswil Grundwasser								
Chlorthalonil-M4 (R471811)	µg/l	<0.05			<0.05			<0.050
Chlorthalonil-M12 (R417888)	µg/l	<0.02			<0.02			<0.025
Fraubrunnen			PW 1	PW 1			PW 1	
Chlorthalonil-M4 (R471811)	µg/l		0.19	0.22			0.27	0.23
Chlorthalonil-M12 (R417888)	µg/l		0.036	0.043			0.05	0.04
Altwyden								
Chlorthalonil-M4 (R471811)	µg/l	0.13				0.11		0.12
Chlorthalonil-M12 (R417888)	µg/l	0.027				<0.02		0.03

Die gemessenen Werte erfüllen die Vorgaben

Die gemessenen Werte erfüllen die Vorgaben nicht